

Test Report No:	061022B		E. Info@griptek.com.au				
Slip Resistance Measurement of New Pedestrian Surfaces: AS4586:2013 Appendix A							
Client:	DW Tiles Pty Ltd - 17 Everley Road, Chester Hill NSW 2162						
Test Date:	6/10/2022	Temperature:	20 Deg C.				
Test Conducted to:	AS 4586:2013 Appendix A	Conducted by:	Sean C Murphy B.A (Syd. U), Dip. Ed				
Test Method:	Wet Pendulum Testing	Test Device:	Munro - Reg. No 2015 Calibration No. AU21/104				
Surface:	Advance Grip	Rubber Slider Used:	Slider 96 (4 S Rubber)				
Slider Preparation:	Abrasive paper, Grade P400 followed by pink lapping paper wet						
Test Location:	17 Everley Road, Chester Hill NSW 2162						
Surface Preparation:	Cleaned with Water & Scrubbing						
Surface Application:	N/A						

Tested Area:

Specimen Number	Location	Condition	Gradient %	Direction of Test	Mean BPN Last 3 swings
1	Loose Sample	As Found	<2.0	N/A	57
2	Loose Sample	As Found	<2.0	N/A	68
3	Loose Sample	As Found	<2.0	N/A	56
4	Loose Sample	As Found	<2.0	N/A	60
5	Loose Sample	As Found	<2.0	N/A	60

Mean BPN Slip Resistance Value - SRV 60

Classification P5



Interpretation of the Wet Pendulum Results				
Classification of pedestrian surface materials according to the AS 4586	Mean BPN			
P5	>54			
P4	45-54			
P3	35-44			
P2	25-34			
P1	12-24			
P0	<12			

Approved Signatory: Michael Holt

teyby

The AS 4586 standard provides a guide & recommendation for use, we recommend that this report be read in conjuction with AS 4586 & Handbook HB198: 2014. Refer to Table 3B of HB 198 for requirements of sloped surfaces & ramps. The results in this test do not account for any future wear, contamination or maintenance of this surface. GripTek Anti-Slip Solutions Pty Ltd or our agents, licencees or employees accept no responsibility for any actions whatsoever which may arise as a result of this test report, all information within this report is copyright & is protected by copyright law.